

---

## Plan Review Summary

---

### Building Information

Project Name:	CODA Tenant Fit Up-Floor 14-16	Floor/Room #:	14-16
Building #:	207	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$23M
Construction Type:	IA	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Devyn Blackstone, HITT
Architect/Engineer of Record:	Kara Thomas/Matt Dipiro
Construction Manager:	Chris Sanders
Aim Project Number:	0009-2017

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	11/28/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	12/4/2018

### Status Statement

Note: Fire Sprinkler installation for Tenant Build-out Floors 14-16

### Review Comments:

1. Please provide an approved method of fire stopping detail for through penetrations in fire rated construction at time of inspection.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Suppression System 2018-FS-394