

Plan Review Summary

Building Information

Project Name:	CODA Tenant Fit Up-Floor 9-11	Floor/Room #:	Floors 9-11
Building #:	207	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$23M
Construction Type:	IB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Devyn Blackstone
Architect/Engineer of Record:	Kara Thomas/Matt Dipiro
Construction Manager:	Chris Sanders
Aim Project Number:	0009-2017

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	12/5/2018
Disposition:	Approved	Date Completed:	12/10/2018

Status Statement

Note: Fire Sprinkler System for Floors

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2018-FS-406