

## Plan Review Summary

### Building Information

Project Name:	CODA Tenant Fit Up Floor 12-13	Floor/Room #:	Floors 12-13
Building #:	207	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$23M
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Devyn Blackstone
Architect/Engineer of Record:	Kara Thomas/Matt DiPiro
Construction Manager:	Chris Sanders
Aim Project Number:	0009-2017

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	12/5/2018
Disposition:	Approved	Date Completed:	12/10/2018

### Status Statement

Note: Fire sprinkler plan CODA

### Review Comments:

1. Approved

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System

### Permits Issued:

1. Fire Suppression System 2018-FS-407