
Plan Review Summary

Building Information

Project Name:	Bunger Henry Prime Lab 341	Floor/Room #:	3rd Floor
Building #:	086	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$2,500
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Ngugi Mathu
Construction Manager:	Fenella Bryant
Aim Project Number:	179-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	3/27/2018
Disposition:	Declined	Date Completed:	4/5/2018

Status Statement

Note: Bunger Henry Prime lab - Addition to current fire alarm system

Review Comments:

1. No scope of work noted, please provide.
2. Provide battery calculations for system with new devices added
3. Provide existing load capacity of panel and noted changes
4. Supply Construction type on plans
5. Supply occupancy type on plans

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Project kick-off meeting
 2. Rough-in
 3. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
 4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
 5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)
-