

---

## Plan Review Summary

---

### Building Information

Project Name:	Cherry Emerson-Roofing Replacement-Scaffolding	Floor/Room #:	Exterior
Building #:	066	Department:	Facilities D & C
Occupancy Type:	Business	Budget:	\$445,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Kynthia Gaines
Architect/Engineer of Record:	Bill Oswell
Construction Manager:	Kynthia Gaines
Aim Project Number:	0124-2017

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/5/2018
Disposition:	Declined	Date Completed:	4/10/2018

---

### Status Statement

Note: Cherry Emerson-Roofing Replacement-Scaffolding

### Review Comments:

1. Please come meet with Fire Marshal to discuss placement

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
  2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
  3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
  4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)
-