

Plan Review Summary

Building Information

Project Name:	MARC Callaway Manufacturing Research	Floor/Room #:	3rd
Building #:	126	Department:	ME
Occupancy Type:	Business	Budget:	\$500,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Bill Oswell
Construction Manager:	Bill Oswell
Aim Project Number:	0094-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/19/2018
Disposition:	Declined	Date Completed:	5/1/2018

Status Statement

Note: Callaway Manufacturing lab

Review Comments:

1. Supply documentation regarding curtains and flammability rating
2. Fire Alarm must cut off and movie or demonstration to allow for evacuation
3. Signage must be place on the door that is not an exit "NOT AN EXIT"
4. Hand rail drawings for both sides of stairs

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Alarm