

---

## Plan Review Summary

---

### Building Information

Project Name:	Van Leer IDC-Evacuation Plan	Floor/Room #:	C0270-2015
Building #:	085	Department:	Electrical and Computer Engineer
Occupancy Type:	Business	Budget:	\$11,000,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Carla Barbour
Architect/Engineer of Record:	BLDGS-Scott Berger
Construction Manager:	Carla Barbour
Aim Project Number:	C0270-2015

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/26/2018
Disposition:	Declined	Date Completed:	5/1/2018

---

### Status Statement

Note: Evacuation Plan

### Review Comments:

1. Plan must be in color and routes must also have different colors.
2. Plan must have proper markings as to fire pull station, fire extinguisher, exits, AED, handicap accessible routes

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
  2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
  3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)
-