

Plan Review Summary

Building Information

Project Name:	Football Locker Room Renovations-Rice Building	Floor/Room #:	1st Floor/Locker Room
Building #:	017	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$4M
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Marc Clear/Heery
Construction Manager:	Bryan Steed/JE Dunn
Aim Project Number:	2018-0050

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/27/2018
Disposition:	Declined	Date Completed:	5/3/2018

Status Statement

Note: Locker room fire sprinklers

Review Comments:

1. Construction type not listed
2. Occupancy type not listed
3. Point of reference not on plans
4. Rooms not labeled
5. Locking FDC caps required on FDC's
6. Provide location of sprinkler box with replacement heads and wrench as prescribed in NFPA 13 6.2.9.5

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation

