

Plan Review Summary

Building Information

Project Name:	Evo Event-Bobby Dodd Stadium	Floor/Room #:	Bodacious Burgers Concession Area
Building #:	017	Department:	Auxiliary Services
Occupancy Type:	Business	Budget:	\$6,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Yara Rymer RLR Architects & Engineers
Construction Manager:	N/A
Aim Project Number:	0174-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/30/2018
Disposition:	Declined	Date Completed:	6/1/2018

Status Statement

Note: Installation of ventless griddle with fire suppression

Review Comments:

1. Please show compliance with the 2011 edition of NFPA 96 10.6.2, and indicate in the system outputs chart that a fire alarm signal will be initiated upon activation of the pull station or fusible link for the cooking appliance
2. Please show the location of the horn/strobe on the fire alarm plans in the kitchen in relation to the cooking appliance in accordance with the 2011 edition of NFPA 96, 10.6.2.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm