
Plan Review Summary

Building Information

Project Name:	Crosland Tower Crane Safety Plan	Floor/Room #:	
Building #:	100	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$50M
Construction Type:	IIB	Type of Review:	Construction-Crane Plan

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	
Construction Manager:	John Fulford/Brasfield & Gorrie
Aim Project Number:	2014-0146

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/20/2018
Disposition:	Declined	Date Completed:	6/20/2018

Status Statement

Note: Crane Plan

Review Comments:

1. Provide documentation that cable has been inspected
2. Provide safety plan

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
 2. Construction / Interior Renovation
-