

## Plan Review Summary

### Building Information

Project Name:	Relocation Tech Wreck to Howell-HOWELL	Floor/Room #:	
Building #:	010	Department:	Grand Challenges LLC
Occupancy Type:	Business	Budget:	\$3,000
Construction Type:	IIB	Type of Review:	Fire Alarm

### Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Tyco Simplex Grinnell
Construction Manager:	Spencer Sheffield
Aim Project Number:	0239-2018

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/25/2018
Disposition:	Declined	Date Completed:	7/2/2018

### Status Statement

Note: Addition of smoke

### Review Comments:

1. Supply Battery Calcs
2. Load test
3. Existing Panel Capacity

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Alarm