
Plan Review Summary

Building Information

Project Name:	GTRI COBB South-1st floor	Floor/Room #:	1st floor
Building #:	762	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$24M
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	FLAD Architects/Structural Engineers
Construction Manager:	Dan Hesse/McCarthy Building Companies
Aim Project Number:	0320-2016

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	8/3/2018
Disposition:	Declined	Date Completed:	Click here to enter a date.

Status Statement

Note: Crane Plan

Review Comments:

1. Copies of operators driver's license and crane operator permit
2. An overview of where the crane will placed on the property
3. Current inspection records on the crane itself.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation

Permits Issued:

1. Demolition
 2. Construction / Interior Renovation
-