

Plan Review Summary

Building Information

Project Name:	Dr. Liu Lab Renovation-MS&E	Floor/Room #:	3rd/3271, 3279, 3250
Building #:	167	Department:	Lab Unit 3
Occupancy Type:	Business	Budget:	\$120,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Tony Gonzalez, GA TECH
Architect/Engineer of Record:	Carlos Perez-Rubio, HERA
Construction Manager:	Fenella Bryant, GA TECH
Aim Project Number:	0111-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	10/15/2018
Disposition:	Declined	Date Completed:	10/26/2018

Status Statement

Note: Lab Renovation

Review Comments:

1. The Class IB Flammable liquids: Ethanol, Isopropanol, Acetone, Methanol, shall be stored in 1Liter glass containers not 2.5 liter glass containers in accordance with the 2011 edition of table 10.1.2.
2. Please provide SDS sheets for all chemicals listed on the Chemical Inventory List
3. Please include all data for the chemicals listed at the bottom of the chemical inventory list.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Demolition
 2. Construction / Interior Renovation
 3. Fire Suppression System
 4. Fire Alarm
-

