

Plan Review Summary

Building Information

Project Name:	Kappa Alpha Theta-Fire Suppression	Floor/Room #:	All-3 Floors
Building #:	Not yet assigned	Department:	Greek Life
Occupancy Type:	Lodging or Rooming House	Budget:	\$4.8M
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Tyler White
Architect/Engineer of Record:	Hug & Associates, Architect
Construction Manager:	Joe Thomason
Aim Project Number:	

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	10/16/2018
Disposition:	Declined	Date Completed:	10/18/2018

Status Statement

Note: Fire Sprinkler System

Review Comments:

1. I did not see the location of the FDC for the system. Please provide the location and have it be remote from the building and accessible from the street.
2. Please provide an approved method of firestopping detail for penetrations through fire rated construction

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Demolition
 2. Construction / Interior Renovation
 3. Fire Suppression System
 4. Fire Alarm
-

