
Plan Review Summary

Building Information

Project Name:	ACC Network Operations Center-Fire Alarm Drawings	Floor/Room #:	First and Second Floors
Building #:	32	Department:	Athletics
Occupancy Type:	Business	Budget:	\$10,000,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Carla Barbour
Architect/Engineer of Record:	Jim Winer-Make3 Arch
Construction Manager:	Carla Barbour
Aim Project Number:	C0404-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	12/3/2018
Disposition:	Declined	Date Completed:	12/4/2018

Status Statement

Note: Fire alarm upgrades

Review Comments:

1. Provide name and credential of engineer
2. Provide battery calculations
3. Alarm panel must tie into Onyx workstation

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Alarm
-