

Plan Review Summary

Building Information

Project Name:	Cicerone Lab Fit-up	Floor/Room #:	G228 (East half) and G264
Building #:	167	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$110,000
Construction Type:	IB	Type of Review:	Construction

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	D&C/RMF Engineering
Construction Manager:	Jennifer Disotell
Aim Project Number:	0087-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	12/17/2018
Disposition:	Declined	Date Completed:	12/20/2018

Status Statement

Note: Laboratory Renovation; fit up

Review Comments:

1. The occupant load should be 6 persons for G228 and 2 persons for G228B. Please revise.
2. Please provide the container material type for chemicals in the chemical inventory list on sheet A101.
3. Please provide a duct smoke detector in the supply side duct and show the location of the test station and audible/visible signal.
4. Please provide the manufacturer specifications of the flammable/combustible liquids cabinet.
5. Please provide locations of portable fire extinguishers.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation

- 2. Fire Suppression System
 - 3. Fire Alarm
-

