

Plan Review Summary

Building Information

Project Name:	CCRF Bldg 5 Renovation	Floor/Room #:	1st Floor
Building #:	805	Department:	GTRI
Occupancy Type:	Business	Budget:	\$2M
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Carl Beasley
Architect/Engineer of Record:	Douglas Bristol
Construction Manager:	Carl Beasley
Aim Project Number:	0211-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	1/7/2019
Disposition:	Approved	Date Completed:	1/7/2019

Status Statement

Note: GTRI Cobb County Building % Reno

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm 2019-CP-008