

Plan Review Summary

Building Information

| | | | |
|--------------------|--|-----------------|--------------|
| Project Name: | 8th Street Apartments Wireless Upgrade | Floor/Room #: | All |
| Building #: | 130 | Department: | GT Housing |
| Occupancy Type: | Apartment Building | Budget: | \$700,000.00 |
| Construction Type: | IIB | Type of Review: | Construction |

Project Management

| | |
|-------------------------------|-------------------|
| Project Manager: | Spencer Sheffield |
| Architect/Engineer of Record: | GT OIT |
| Construction Manager: | Spencer Sheffield |
| Aim Project Number: | 0123-2019 |

Reviewer Information

| | | | |
|----------------|--------------|-----------------|-----------|
| Reviewer Name: | Jake LeJeune | Date Received: | 1/9/2019 |
| Disposition: | Approved | Date Completed: | 1/10/2019 |

Status Statement

Note: Data Cabling and Wireless Upgrade; Through Penetration in Fire Rated walls and floors

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Per

Permits Issued:

- | | |
|---------------------------------------|-------------|
| 1. Construction / Interior Renovation | 2019-CP-010 |
|---------------------------------------|-------------|