
Plan Review Summary

Building Information

Project Name:	Paper Tricentennial-Replacement from Diesel to Gas	Floor/Room #:	Outside
Building #:	129	Department:	Environmental, Health & Safety
Occupancy Type:	Other	Budget:	\$33,000.00
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Tony Gonzalez
Architect/Engineer of Record:	
Construction Manager:	
Aim Project Number:	2018-PFR-2579

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	1/11/2019
Disposition:	Approved	Date Completed:	1/11/2019

Status Statement

Note: Diesel Replacement Tank; 350 gallons for generator

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2019-CP-012
-