

Plan Review Summary

Building Information

Project Name:	The Living Building-Kendeda (PV)	Floor/Room #:	All
Building #:	210	Department:	Facilities
Occupancy Type:	Business	Budget:	\$18.6M
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	John DuConge
Architect/Engineer of Record:	Joshua Gassman
Construction Manager:	Matt Williams
Aim Project Number:	0418-2017

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	2/1/2019
Disposition:	Approved	Date Completed:	2/4/2019

Status Statement

Note: Photovoltaic and Energy Storage Systems

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2019-CP-027