
Plan Review Summary

Building Information

| | | | |
|--------------------|-----------------------------------|-----------------|----------------------------------|
| Project Name: | GESPC Controls Upgrade Initiative | Floor/Room #: | 3321/3325 |
| Building #: | 147 | Department: | Facilities Design & Construction |
| Occupancy Type: | Business | Budget: | \$93,000 |
| Construction Type: | IIB | Type of Review: | Construction |

Project Management

| | |
|-------------------------------|--------------------------------|
| Project Manager: | Greg Spiro |
| Architect/Engineer of Record: | Walker Jones, Newcomb and Boyd |
| Construction Manager: | Kyntha Gaines |
| Aim Project Number: | C0378-2018 |

Reviewer Information

| | | | |
|----------------|--------------|-----------------|-----------|
| Reviewer Name: | Jake LeJeune | Date Received: | 2/20/2019 |
| Disposition: | Approved | Date Completed: | 2/21/2019 |

Status Statement

Note: Mechanical/fume hood ducts

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2019-CP-044
-