

Fire Safety

Plan Review Summary

Building Information			
Project Name:	Hefner and Armstrong Renovations(Honors Program)	Floor/Room #:	1st Floors and minor upper floors
Building #:	107 &108	Department:	Center for Academic Enrichment & Housing
Occupancy Type:	Dormitory	Budget:	\$250,000
Construction Type:	IIB	Type of Review:	Construction
Project Management			
Project Manager:	Daniel Powell		
Architect/Engineer of	Record: Todd Gilbert		
Construction Manage	er:		
Aim Project Number:	0066-2019		
Reviewer Information			
Reviewer Name:	Jake LeJeune	Date Received:	3/11/2019

Date Completed:

3/14/2019

Status Statement

Disposition:

Note: Renovations

General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

- 1. Fire Suppression
- 2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting

Approved

- 2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

- 1. Construction / Interior Renovation
- 2. Fire Suppression System
- 3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation

2019-CP-064