
Plan Review Summary

Building Information

Project Name:	Motor Pool Standby Generator	Floor/Room #:	All Buildings not including B161
Building #:	B067,067A,B083C,B161	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$150,000 to \$200,000
Construction Type:	IIIA	Type of Review:	Construction

Project Management

Project Manager:
Architect/Engineer of Record: Dennis G. Carter
Construction Manager:
Aim Project Number: 0312-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	3/12/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/13/2019

Status Statement

Note: Addition of a gas fed stand-by generator

Review Comments:

1. Warning sign must be provided (Specs can be found under GTFISO website)
2. Plunger disconnect must be provided
3. Gas lines must be labeled

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation

Permits Issued:

1. Construction / Interior Renovation
-

2019-CP-070