
Plan Review Summary

Building Information

Project Name:	Howell Residence Hall-Emergency Generator Replacement	Floor/Room #:	
Building #:	010	Department:	GT Housing
Occupancy Type:	Business	Budget:	\$200,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Robertson Loia Roof
Construction Manager:	Spencer Sheffield
Aim Project Number:	0466-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	3/13/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/13/2019

Status Statement

Note: Replacement of emergency generator

Review Comments:

1. This is for construction only, separate permit and submittal required for generator itself.
- 2.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation

Permits Issued:

1. Construction / Interior Renovation
-

2019-CP-072