Plan Review Summary

151 Sixth Street, Suite 341 Atlanta, Georgia 30332 404-894-FIRE (3473)

Georgia Environmental Tech Health & Safety

Fire Safety

Building Information			
Project Name:	Dr. Chen Lab 401-Montgomery Knight	Floor/Room #:	401
Building #:	101	Department:	Aerospace Engineering
Occupancy Type:	Business	Budget:	\$200,000
Construction Type:	IIB	Type of Review:	Construction
Project Management			
Project Manager:	Maria del Mar Ceballos		
Architect/Engineer of Record: Maria del Mar Ceballos			
Construction Manager: Mitchell Shelton			
Aim Project Number:	0285-2019		
Reviewer Information			
Reviewer Name:	Jake LeJeune	Date Received:	3/18/2019
Disposition:	Approved	Date Completed:	3/20/2019
General Note: 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work 3. Plan / Shop Drawings Required: 1. Fire Alarm Inspections Required:			
 Fire Safety Office Project Kick-Off Meeting 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.) 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.) 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.) 			
Permits Required:			
1. Fire Alarm	. Fire Alarm		
Permits Issued:			

1. Construction / Interior Renovation

2019-CP-075