
Plan Review Summary

Building Information

Project Name:	Montgomery Knight-Room 308 Refresh	Floor/Room #:	308
Building #:	101	Department:	Aerospace
Occupancy Type:	Business	Budget:	\$15,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Allison Gertsung
Architect/Engineer of Record:	William T. Oswell
Construction Manager:	
Aim Project Number:	0198-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/25/2019
Disposition:	Approved	Date Completed:	3/25/2019

Status Statement

Note: Room Dividers installed in room 308

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2019-CP-085
-