
Plan Review Summary

Building Information

Project Name:	831 Marietta Street Lab Complex	Floor/Room #:	1, 139, 148, 149
Building #:	184	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$490,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Maria del Mar Ceballos
Architect/Engineer of Record:	Darrell Fitzgerald-POC: Kelvin Hall
Construction Manager:	Mitchell Shelton
Aim Project Number:	0165-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/15/2019
Disposition:	Approved	Date Completed:	4/16/2019

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 2019-CP-113
-