

151 Sixth Street, Suite 341 Atlanta, Georgia 30332 404-894-FIRE (3473)

Plan Review Summary

Building Information

Project Name: Locker & Toilet Partition Renovation-CRC

160

IIB

Business

Floor/Room #:

Multiple Locker Rooms &

_ .

Restrooms

Department:

CRC

Budget:

\$435,000.00

Tvr

Type of Review: Construction

Project Management

Project Manager:

Daniel Powell

Architect/Engineer of Record:

Jessicalia McFarlane

Construction Manager:

Aim Project Number:

077-2019

Reviewer Information

Reviewer Name: Jake LeJeune

Date Received:

4/26/2019

Approved

Date Completed:

4/29/2019

General Note:

Disposition:

Building #:

Occupancy Type:

Construction Type:

1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request

Plan / Shop Drawings Required:

- 1. Fire Suppression
- 2. Fire Alarm

Inspections Required:

- Fire Safety Office Project Kick-Off Meeting
- 2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

- 1. Construction / Interior Renovation
- 2. Fire Suppression System
- 3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation

2019-CP-139