

---

## Plan Review Summary

---

### Building Information

Project Name:	Dalney Building-Signage Plan	Floor/Room #:	All
Building #:	204	Department:	GTRC(Office), PTS(Garage)
Occupancy Type:	Business	Budget:	\$39M
Construction Type:	IIB	Type of Review:	Construction-Signage Plan

---

### Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Scott Southerland, Collins Cooper Carusi
Construction Manager:	Ryan Clear, New South Construction
Aim Project Number:	0370-2017

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/3/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/10/2019

---

### Status Statement

Note: Signage plan submittal

### Review Comments:

1. EVAC Maps are required at elevators
2. Stairwell signage is required per NFPA 101

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation

### Permits Issued:

1. Construction / Interior Renovation

2019-CP-148

---