

## Plan Review Summary

### Building Information

Project Name:	Freight Elevator Renovation-Edge Building	Floor/Room #:	
Building #:	018	Department:	Facilities Operations & Management
Occupancy Type:	Business	Budget:	\$60,000
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	Jamie Ready
Architect/Engineer of Record:	Sheffer & Grant Architects (George)
Construction Manager:	Fenella Bryant
Aim Project Number:	0135-2019

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/10/2019
Disposition:	Approved	Date Completed:	5/10/2019

**Status Statement**

Note: Elevator reno

**Review Comments:**

1. Submitted plans approved

**General Note:**

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

**Plan / Shop Drawings Required:**

1. Fire Suppression
2. Fire Alarm

**Inspections Required:**

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

**Permits Required:**

1. Construction / Interior Renovation

**Permits Issued:**

- |                                       |             |
|---------------------------------------|-------------|
| 1. Construction / Interior Renovation | 2019-CP-154 |
|---------------------------------------|-------------|