

---

## Plan Review Summary

---

### Building Information

Project Name:	ROTC Interiors-O'Keefe	Floor/Room #:	1st and 2nd Floors
Building #:	033	Department:	Facilities D&C
Occupancy Type:	Business	Budget:	\$999,999
Construction Type:	IIB	Type of Review:	Construction-Revision

---

### Project Management

Project Manager:	
Architect/Engineer of Record:	Warner Summers
Construction Manager:	Mitchell Shelton
Aim Project Number:	0421-2018

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/10/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/14/2019

---

### Status Statement

Note: O'Keefe Reno for Military floors

### Review Comments:

1. Max occupant Load Signs must be posted in all classrooms, meeting rooms and training room
2. Fire extinguisher spacing must meet NFPA 10

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation

### Permits Issued:

1. Construction / Interior Renovation                      2019-CP-155
-