
Plan Review Summary

Building Information

Project Name:	Campus Recreation Center Batting Cage	Floor/Room #:	
Building #:	160	Department:	CRC
Occupancy Type:	Other	Budget:	\$75,000.00
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Anthony Gonzalez
Architect/Engineer of Record:	Alan Wieczynski
Construction Manager:	Daniel Powell
Aim Project Number:	0500-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/30/2019
Disposition:	Approved	Date Completed:	5/30/2019

Status Statement

Note: Light change out (bulb) switch

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation

Permits Issued:

1. Construction / Interior Renovation 2019-CP-170
-