

## Plan Review Summary

### Building Information

|                    |                                    |                 |              |
|--------------------|------------------------------------|-----------------|--------------|
| Project Name:      | Klemis Kitchen Renovation-MSE/Ford | Floor/Room #:   | Basement     |
| Building #:        | 167/147                            | Department:     | Other        |
| Occupancy Type:    | Other                              | Budget:         | \$10,000.00  |
| Construction Type: | IIB                                | Type of Review: | Construction |

### Project Management

|                               |                        |
|-------------------------------|------------------------|
| Project Manager:              | Maria del Mar Ceballos |
| Architect/Engineer of Record: | Maria del Mar Ceballos |
| Construction Manager:         | Daniel Powell          |
| Aim Project Number:           | 0196-2019              |

### Reviewer Information

|                |                                     |                 |           |
|----------------|-------------------------------------|-----------------|-----------|
| Reviewer Name: | Jerry Marrison                      | Date Received:  | 5/30/2019 |
| Disposition:   | Approved w/ Additional Requirements | Date Completed: | 5/31/2019 |

### Status Statement

Note: Reno of kitchen moving of a strobe

### Review Comments:

1. Please ensure proper fire extinguisher is in that area

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation

### Permits Issued:

1. Construction / Interior Renovation

2019-CP-171