

## Plan Review Summary

### Building Information

Project Name:	Vamvoudakis Lab-Montgomery Knight	Floor/Room #:	Floor 1 rooms 101 and 103
Building #:	101	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$250,000
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	William T. Oswell
Architect/Engineer of Record:	William T. Oswell
Construction Manager:	Mitchell Shelton
Aim Project Number:	0004-2019

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/10/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/18/2019

### Status Statement

Note: Changing of room and addition of sprinkler

### Review Comments:

1. Submit fire flow calculations with sprinkler plan

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System
2. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation 2019-CP-186