
Plan Review Summary

Building Information

Project Name:	Smith-Brown Residence Halls-Generator ONLY	Floor/Room #:	
Building #:	006/007	Department:	GT Housing
Occupancy Type:	Dormitory	Budget:	\$400,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Roberstson Loia Roof
Construction Manager:	Spencer Sheffield
Aim Project Number:	0465-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/12/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/13/2019

Status Statement

Note: Generator replacement

Review Comments:

1. Waning sign must be placed on building, see approved sign sheet

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work
- 1.

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2019-CP-187
-