

Plan Review Summary

Building Information

Project Name:	Global Learning Center Room 235 Renovation	Floor/Room #:	2nd Floor/Room 235
Building #:	170	Department:	Gt Professional Education
Occupancy Type:	Assembly	Budget:	\$150,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Amber Chellis-Omedo
Architect/Engineer of Record:	Amber Chellis-Omedo
Construction Manager:	Fenella Bryant
Aim Project Number:	0350-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/12/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/13/2019

Status Statement

Note: Assembly reno

Review Comments:

1. Please make sure Maximum Occupancy signs are posted by doors.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 201-CP-191