

## Plan Review Summary

### Building Information

|                    |                                |                 |                                    |
|--------------------|--------------------------------|-----------------|------------------------------------|
| Project Name:      | Campus Center-Phase 1 PAVILION | Floor/Room #:   |                                    |
| Building #:        | 215                            | Department:     | Facilities-Design and Construction |
| Occupancy Type:    | Business                       | Budget:         | \$4,050,000.00                     |
| Construction Type: | IIB                            | Type of Review: | Construction                       |

### Project Management

|                               |                          |
|-------------------------------|--------------------------|
| Project Manager:              | John DuConge             |
| Architect/Engineer of Record: | Cooper Carry Inc.        |
| Construction Manager:         | Gilbane Building Company |
| Aim Project Number:           | BOR-PPV-30-1801          |

### Reviewer Information

|                |              |                 |           |
|----------------|--------------|-----------------|-----------|
| Reviewer Name: | Jake LeJeune | Date Received:  | 8/2/2019  |
| Disposition:   | Approved     | Date Completed: | 9/13/2019 |

### **General Note:**

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### **Additional Requirements (as needed):**

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### **Plan / Shop Drawings Required:**

1. Fire Suppression
2. Fire Alarm

### **Inspections Required:**

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### **Permits Required:**

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

**Permits Issued:**

1. Construction / Interior Renovation

2019-CP-255

---

