

Plan Review Summary

Building Information

Project Name:	Georgia Power/Georgia Tech Microgrid	Floor/Room #:	Ground Street Level
Building #:	174	Department:	PowerSecure Inc./Josh Burns
Occupancy Type:	Business	Budget:	\$4,436,605.00
Construction Type:	IIB	Type of Review:	Construction-REVISION

Project Management

Project Manager:	Colin O'Neill
Architect/Engineer of Record:	Martin Leibold
Construction Manager:	Joshua Burns
Aim Project Number:	

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/21/2019
Disposition:	Approved	Date Completed:	8/26/2019

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

- | | |
|---------------------------------------|-------------|
| 1. Construction / Interior Renovation | 2019-CP-277 |
|---------------------------------------|-------------|