
Plan Review Summary

Building Information

Project Name:	There Gastropub on 5th Tenant Upfit	Floor/Room #:	Ground Floor
Building #:	172	Department:	Auxiliary Services
Occupancy Type:	Business	Budget:	\$230,000
Construction Type:	IIB	Type of Review:	Construction-Revision

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Levi Salazar Tect Design Build
Construction Manager:	
Aim Project Number:	0270-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/22/2019
Disposition:	Approved	Date Completed:	8/28/2019

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

2019-CP-280
