

## Plan Review Summary

### Building Information

Project Name:	Woodshop/Dust Collection System	Floor/Room #:	2317
Building #:	135	Department:	School of Mech. Engr.
Occupancy Type:	Business	Budget:	\$200,000
Construction Type:	IIIB	Type of Review:	Construction

### Project Management

Project Manager:	Tony Gonzalez
Architect/Engineer of Record:	Eric Clementi, Schneider Wright Inc.
Construction Manager:	Jennifer Disotell
Aim Project Number:	0452-2019

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	10/14/2019
Disposition:	Approved	Date Completed:	10/15/2019

### Status Statement

Note: Dust collector

### Review Comments:

1. Approved

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation 2019-CP-314