
Plan Review Summary

Building Information

Project Name:	Price Gilbert Library Renewal- Grass Pave	Floor/Room #:	Site-Product for Fire Lane
Building #:	100	Department:	Design and Construction
Occupancy Type:	Business	Budget:	
Construction Type:	VA	Type of Review:	Construction

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Jermy Kahm
Construction Manager:	Ryan Miller
Aim Project Number:	

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	10/24/2019
Disposition:	Approved	Date Completed:	10/25/2019

Status Statement

Note: Fire lane surface plan

Review Comments:

1. Fire Lane Signs will be required

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Lane 2019-CP-323
-