
Plan Review Summary

Building Information

| | | | |
|--------------------|--|-----------------|--------------------|
| Project Name: | Price Gilbert Crosland Library-Sideways Cafe | Floor/Room #: | Ground Floor/G110 |
| Building #: | 100/077 | Department: | Auxiliary Services |
| Occupancy Type: | Business | Budget: | \$150,000.00 |
| Construction Type: | IIB | Type of Review: | Construction |

Project Management

| | |
|-------------------------------|---------------|
| Project Manager: | Daniel Powell |
| Architect/Engineer of Record: | Brian Tanner |
| Construction Manager: | |
| Aim Project Number: | 0368-2019 |

Reviewer Information

| | | | |
|----------------|--------------|-----------------|------------|
| Reviewer Name: | Jake LeJeune | Date Received: | 10/24/2019 |
| Disposition: | Approved | Date Completed: | 10/29/2019 |

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2019-CP-324
-