
Plan Review Summary

Building Information

Project Name:	Bobby Dodd Stadium Lighting	Floor/Room #:	
Building #:	017	Department:	GTAA
Occupancy Type:	Business	Budget:	\$1,850,000.00
Construction Type:	IIA	Type of Review:	Construction

Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Matt Kastel
Construction Manager:	Mark Wood
Aim Project Number:	0218-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	11/15/2019
Disposition:	Approved	Date Completed:	11/21/2019

Status Statement

Note: Changing lights adding new panel

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction 2019-CP-336
-