

## Plan Review Summary

### Building Information

Project Name:	Alumni House Replacement-Phase 2	Floor/Room #:	1st and 2nd Floor
Building #:	003	Department:	GT Alumni Association
Occupancy Type:	Business	Budget:	\$789,000.00
Construction Type:	IIIB	Type of Review:	Construction

### Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Gabe Park
Construction Manager:	Mark Wood
Aim Project Number:	0074-2020

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	12/3/2019
Disposition:	Approved	Date Completed:	12/5/2019

### Status Statement

Note: AHU Replacement

### Review Comments:

1. Approved

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation 2019-CP-346