

Plan Review Summary

Building Information

Project Name:	Fourth Floor Open Office Expansion-GPB	Floor/Room #:	4th Floor
Building #:	141A	Department:	GTRI Support Services
Occupancy Type:	Business	Budget:	\$400,000
Construction Type:	IIIA	Type of Review:	Construction

Project Management

Project Manager:	Jennifer Disotell
Architect/Engineer of Record:	Concord Consulting
Construction Manager:	Ross Bongiovi
Aim Project Number:	0407-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	12/11/2019
Disposition:	Approved	Date Completed:	12/18/2019

Status Statement

Note: Renovation of 4th floor, removal of walls and changing location of devices

Review Comments:

1. This is approval of the construction aspect only, fire alarm submittals and sprinkler submittals must be supplied

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Rough-in
3. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

