

Plan Review Summary

Building Information

Project Name:	CNES-Room 128-Adam Steinberg Research Laboratory	Floor/Room #:	1st Floor/Room 128
Building #:	199	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$250,000.00
Construction Type:	IIB	Type of Review:	Construction-REVISION

Project Management

Project Manager:	Greg Spiro
Architect/Engineer of Record:	Integrated Engineering Services/Mark Bertz
Construction Manager:	Cristina Fannin
Aim Project Number:	0078-2016

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	12/19/2019
Disposition:	Approved	Date Completed:	2/20/2020

Status Statement

Note: Revision 2

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2019-CP-360