
Plan Review Summary

Building Information

Project Name:	ULC Boiler Replacement	Floor/Room #:	Mechanical G06
Building #:	064	Department:	Housing
Occupancy Type:	Business	Budget:	\$921,317.00
Construction Type:	IIIB	Type of Review:	Construction

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Thom Wille
Construction Manager:	
Aim Project Number:	0217-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	12/19/2019
Disposition:	Approved	Date Completed:	12/30/2019

Status Statement

Note: Boiler replacement

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction 2019-CP-361
-