
Plan Review Summary

Building Information

Project Name:	DM Smith-RTU Coil Replacement (0837B18)	Floor/Room #:	Roof
Building #:	024	Department:	Facilities/Maintenance Area 4
Occupancy Type:	Business	Budget:	\$10,688
Construction Type:	IIB	Type of Review:	Construction-Crane Plan

Project Management

Project Manager:
Architect/Engineer of Record: Federico Del Risco
Construction Manager:
Aim Project Number:

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/1/2019
Disposition:	Approved w/ Additional Requirements	Date Completed:	7/1/2019

Status Statement

Note: Crane

Review Comments:

1. The crane shall only swing a 90 degree distance from the truck to the building's roof. The No Fly Zone shall be 270 degrees.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Crane Plan: 2019-CPL-208
-