

---

## Plan Review Summary

---

### Building Information

Project Name:	GTRI Cobb South-Fire Alarm L12	Floor/Room #:	L-12
Building #:	763	Department:	Gt Design and Construction
Occupancy Type:	Business	Budget:	\$24M
Construction Type:	IIB	Type of Review:	Fire Alarm

---

### Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	FLAD Architects/Structural Engineers
Construction Manager:	Dan Hesse/McCarthy Building Companies
Aim Project Number:	0320-2016

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	1/11/2019
Disposition:	Approved	Date Completed:	1/23/2019

---

### Status Statement

Note: Fire Alarm System Installation

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued: Fire Alarm: 2019-FA-013

---