
Plan Review Summary

Building Information

Project Name:	CODA Tenant Fit Up Floors 12 & 13	Floor/Room #:	Floors 12 & 13
Building #:	207	Department:	Facilities Design and Construction
Occupancy Type:	Business	Budget:	\$35M
Construction Type:	IB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Devyn Blackston
Architect/Engineer of Record:	Matt DiPiro
Construction Manager:	Chris Sanders
Aim Project Number:	0009-2017

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	1/14/2019
Disposition:	Approved	Date Completed:	2/6/2019

Status Statement

Note: Fire Alarm System Installation; 12 & 13 floors

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

2019-FA-014
